



Product Service


CERTIFICATE

No. Z2 110727 0005 Rev. 01

Holder of Certificate: **SSWISS GROUP AG**

Baarerstrasse 25
6300 ZUG
SWITZERLAND

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262213703-01

Valid until: 2028-08-21

Date, 2025-06-10

(Zhulin Zhang)

CERTIFICATE

No. Z2 110727 0005 Rev. 01

Model(s):

IBEX-144MHC COSMOS xxx, xxx=390-455 in step of 5;
IBEX-120MHC COSMOS xxx, xxx=325-380 in step of 5;
IBEX-132MHC COSMOS xxx, xxx=385-415, in step of 5;
IBEX-156MHC EiGER xxx, xxx=550-605, in step of 5;
IBEX-144MHC EiGER xxx, xxx=510-555, in step of 5;
IBEX-132MHC EiGER xxx, xxx=470-510, in step of 5;
IBEX-120MHC EiGER xxx, xxx=425-465, in step of 5;
IBEX-108MHC EiGER xxx, xxx=390-415, in step of 5;
IBEX-66M EiGER HP xxx, xxx=635-675, in step of 5;
IBEX-60M EiGER HP xxx, xxx=580-610, in step of 5.
xxx is standing for rated output power at STC.

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
IEC 62716:2013